

Appendix G - Noise Monitoring Results

(0700-1900 hrs on Normal Weekdays)

| Location CM1 - Nga Lai House, Yau Lai Estate Phase 1, Yau Tong | | | | | | | |
|--|-------|---------|-----------------------|-----------------|-----------------|-----------------|--------------------------|
| Date | Time | Weather | Unit: dB (A) (30-min) | | | | |
| | | | Measured Noise Level | | | Baseline Level | Construction Noise Level |
| | | | L _{eq} | L ₁₀ | L ₉₀ | L _{eq} | L _{eq} |
| 6 Jun 2024 | 11:44 | Fine | 69.4 | 70.6 | 67.9 | 65.5 | 67 |
| 12 Jun 2024 | 15:30 | Cloudy | 67.7 | 68.9 | 66.6 | 65.5 | 64 |
| 18 Jun 2024 | 16:03 | Fine | 69.1 | 70.3 | 67.6 | 65.5 | 67 |
| 24 Jun 2024 | 15:21 | Fine | 68.0 | 69.6 | 66.2 | 65.5 | 64 |




| Location CM2 - Bik Lai House, Yau Lai Estate Phase 1, Yau Tong | | | | | | | |
|--|-------|---------|-----------------------|-----------------|-----------------|-----------------|--------------------------|
| Date | Time | Weather | Unit: dB (A) (30-min) | | | | |
| | | | Measured Noise Level | | | Baseline Level | Construction Noise Level |
| | | | L _{eq} | L ₁₀ | L ₉₀ | L _{eq} | L _{eq} |
| 6 Jun 2024 | 12:23 | Fine | 69.3 | 70.5 | 67.9 | 63.6 | 68 |
| 12 Jun 2024 | 14:32 | Cloudy | 68.0 | 69.1 | 66.7 | 63.6 | 66 |
| 18 Jun 2024 | 14:55 | Fine | 68.2 | 69.5 | 66.8 | 63.6 | 66 |
| 24 Jun 2024 | 14:33 | Fine | 67.2 | 68.6 | 65.6 | 63.6 | 65 |

| Location CM3 - Block S, Yau Lai Estate Phase 5, Yau Tong | | | | | | | |
|--|-------|---------|-----------------------|-----------------|-----------------|-----------------|--------------------------|
| Date | Time | Weather | Unit: dB (A) (30-min) | | | | |
| | | | Measured Noise Level | | | Baseline Level | Construction Noise Level |
| | | | L _{eq} | L ₁₀ | L ₉₀ | L _{eq} | L _{eq} |
| 6 Jun 2024 | 13:12 | Fine | 64.0 | 64.5 | 62.5 | 65.6 | 64 Measured ≤ Baseline |
| 12 Jun 2024 | 16:40 | Cloudy | 68.4 | 69.3 | 67.0 | 65.6 | 65 |
| 18 Jun 2024 | 14:05 | Fine | 66.7 | 67.9 | 65.4 | 65.6 | 60 |
| 24 Jun 2024 | 16:16 | Fine | 66.1 | 67.1 | 64.7 | 65.6 | 56 |

| Location CM4 - Tin Hau Temple, Cha Kwo Ling | | | | | | | |
|---|-------|---------|-----------------------|-----------------|-----------------|-----------------|--------------------------|
| Date | Time | Weather | Unit: dB (A) (30-min) | | | | |
| | | | Measured Noise Level | | | Baseline Level | Construction Noise Level |
| | | | L _{eq} | L ₁₀ | L ₉₀ | L _{eq} | L _{eq} |
| 6 Jun 2024 | 10:48 | Fine | 59.4 | 61.7 | 54.7 | 62.0 | 59 Measured ≤ Baseline |
| 12 Jun 2024 | 12:06 | Cloudy | 56.1 | 58.8 | 51.2 | 62.0 | 56 Measured ≤ Baseline |
| 18 Jun 2024 | 12:31 | Fine | 58.4 | 61.0 | 53.9 | 62.0 | 58 Measured ≤ Baseline |
| 24 Jun 2024 | 11:54 | Fine | 58.8 | 60.9 | 54.8 | 62.0 | 59 Measured ≤ Baseline |



| Location CM5 - CCC Kei Faat Primary School, Yau Tong | | | | | | | |
|--|-------|---------|-----------------------|-----------------|-----------------|-----------------|--------------------------|
| Date | Time | Weather | Unit: dB (A) (30-min) | | | | |
| | | | Measured Noise Level | | | Baseline Level | Construction Noise Level |
| | | | L _{eq} | L ₁₀ | L ₉₀ | L _{eq} | L _{eq} |
| 6 Jun 2024 | 13:58 | Fine | 68.8 | 71.3 | 65.2 | 68.2 | 60 |
| 12 Jun 2024 | 13:17 | Cloudy | 65.8 | 67.6 | 62.4 | 68.2 | 66 Measured ≤ Baseline |
| 18 Jun 2024 | 13:22 | Fine | 67.4 | 69.6 | 63.9 | 68.2 | 67 Measured ≤ Baseline |
| 24 Jun 2024 | 12:55 | Fine | 66.8 | 69.1 | 63.4 | 68.2 | 67 Measured ≤ Baseline |

Noise Levels



| | | | |
|--|--------------------------------------|---|--|
| Title Contract No. ED/2018/04 Trunk Road T2 and Infrastructure Works for Developments at the Former South Apron Graphical Presentation of Construction Noise Monitoring Results | Scale N.T.S Date Jun 24 | Project No. MA20003 Appendix G | |
|--|--------------------------------------|---|--|

Noise Levels



Notes:

- 1) The major activitie(s) being carried out on site during the reporting period is/are presented in Section 1.10
- 2) The weather conditions during the reporting month are presented in Appendix C.
- 3) Other factors which might affect the monitoring results are presented in Section 3.13.

| | | | |
|--|--------|-------------|----------|
| Title Contract No. ED/2018/04 Trunk Road T2 and Infrastructure Works for Developments at the Former South Apron Graphical Presentation of Construction Noise Monitoring Results | Scale | Project | CINOTECH |
| | N.T.S | No. MA20003 | |
| | Date | Appendix | |
| | Jun 24 | G | |