

MATERIALAB CONSULTANTS LIMITED

Room 723 & 725, 7/F, Block B,
 Profit Industrial Building,
 1-15 Kwai Fung Crescent, Kwai Fong,
 Hong Kong.

Tel : (852)-24508238
 Fax : (852)-24508032
 Email : mcl@fugro.com


Environmental Complaints Log

Reference No.	Date of Complaint Received	Received From	Received By	Nature of Complaint	Date of Investigation	Outcome	Date of Reply
20161207_complaint_c	7 Dec 2016	EPD	Andy Choy (CRBC)	Air	13 Feb 2017	Project-related	13 Feb 2017
20170209_complaint_c	9 Feb 2017	EPD	Andy Choy (CRBC)	Air	22 Feb 2017	Not Project-related	7 Mar 2017
20170502_complaint_c	2 May 2017	CEDD	Andy Choy (CRBC)	Noise	4 May 2017	Not Valid	22 May 2017
20170716_complaint_a	16 July 2017	CEDD	HMJV	Water Quality	4 Aug 2017	Not Project-related	4 Aug 2017
20180530_complaint	30 May 2018	EPD	CRBC	Air	9 June 2018	Not Valid	20 June 2018

Cumulative Statistics on Complaints

Environmental Parameters	Cumulative No. Brought Forward	No. of Complaints This Month	Cumulative Project-to-Date
Air	3	0	3
Noise	1	0	1
Water	1	0	1
Waste	0	0	0
Total	0	0	0

Cumulative Statistics on Notification of Summons and Successful Prosecutions

Environmental Parameters	Cumulative No. Brought Forward	No. of Notification of Summons and Prosecutions This Month	Cumulative Project-to-Date
Air	0	0	0
Noise	0	0	0
Water	0	0	0
Waste	0	0	0
Total	0	0	0

Notification of Environmental Complaints

To : China Road and Bridge Co.
Kai Tak Development- Strage 3 Infrastructure Works for Developments at
the Southern parts of the Former Runway
CEDD Contract No.: KL/2014/03

Attn.: Calvin So Phone: 9724 6254
Email: calvin.so@crbc.com.hk Fax : 2283 1689

cc : CEDD

Attn: Ms. Inness CHAN Phone: 35792454
Email: fpchan@cedd.gov.hk Fax : 35794516

EPD ref.: 18-13537

Dear Sirs,

The EPD received an environmental complaint from public. Please take necessary actions to avoid causing environmental nuisance. If you need further information, please contact me (2117 7572) or our Mr. Wong at 2117 7580.

Date of Complaint received: 30 May 2018

Details of Complaint:

- Complainant quoted some large stockpiles (位於國際展貿中心西南方，啟福道與承昌道之間的地盤) were found uncovered and dust emission was observed during excavation.

-

Advice:

- Comply with APCO (Construction Dust) Regulation is a must.
- Please strengthen the dust suppression measures during your construction works.

Date of notification: 08 June 2018

Environmental Protection Department
Regional Office (East)
Will KWOK, SI[RE]52

Investigation Report for the Complaint Received on 30 May 2018

Reference No.:	20180530_complaint
Project:	Contract KL/2014/03 – Kai Tak Development – Stage 3 Infrastructure Works for Developments at the Southern Part of the Former Runway
Date of Complaint:	30 May 2018
Background:	<p>A complaint received on 30 May 2018 was referred from EPD regarding some large stockpiles were found uncovered and dust emission was observed during excavation (the site between Kai Fuk Road and Shing Cheong Road, Southwest of Kowloon Bay International Trade & Exhibition Center).</p> <p>The notification of complaint was received by ET on 9 June 2018.</p>
Action taken during the investigation and the investigation results	<ul style="list-style-type: none">Joint site inspection was carried out by ET, HMJV and CRBC on 31 May 2018, by ET, IEC, HMJV and CRBC on 7 and 14 June 2018. <p>It was observed that:</p> <ul style="list-style-type: none">Open stockpiles of construction materials at Portion I were covered with impermeable sheeting and kept moist to prevent the dust emission;Hydroseeding was provided and developed on the surface of the stockpiling materials to protect the soil surface to reduce dust emission;No dust emission was observed during excavation.
Conclusion	The complaint received on 30 May 2018 is not valid.

Prepared by: Janet Yu

Certified by: Colin Yung

Designation: Environmental Team Leader

Signature: 

Date: 19 June 2018

Site inspection photos (31 May 2018)_Portion I



Site inspection photos (7 June 2018)_Portion I



Site inspection photos (14 June 2018)_Portion I



MATERIALAB CONSULTANTS LIMITED

Room 723 & 725, 7/F, Block B,
Profit Industrial Building,
1-15 Kwai Fung Crescent, Kwai Fong,
Hong Kong.

Tel : (852)-24508238
Fax : (852)-24508032
Email : mcl@fugro.com

MaterialLab

Site inspection photos (14 June 2018)_Portion K

