

## Appendix H - Noise Monitoring Results

(0700-1900 hrs on Normal Weekdays)

Location CKL1 - Flat 121 Cha Kwo Ling Village							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L <sub>eq</sub>	L <sub>10</sub>	L <sub>90</sub>	L <sub>eq</sub>	L <sub>eq</sub>
3-Jan-25	11:25	Fine	73.8	75.9	62.0	72.4	68
9-Jan-25	10:34	Sunny	75.0	78.6	66.4	72.4	72
15-Jan-25	10:30	Fine	74.4	78.0	65.0	72.4	70
21-Jan-25	11:35	Fine	74.9	78.6	67.1	72.4	71
27-Jan-25	10:00	Fine	74.6	78.5	61.6	72.4	71



Location CKL2 - Flat 103 Cha Kwo Ling Village							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L <sub>eq</sub>	L <sub>10</sub>	L <sub>90</sub>	L <sub>eq</sub>	L <sub>eq</sub>
3-Jan-25	13:00	Fine	73.9	76.4	65.3	71.4	70
9-Jan-25	11:08	Sunny	74.5	78.7	61.8	71.4	72
15-Jan-25	11:00	Fine	75.0	78.6	62.1	71.4	73
21-Jan-25	12:15	Fine	76.0	79.6	65.7	71.4	74
27-Jan-25	10:35	Fine	74.3	78.0	61.1	71.4	71

Location KTD1 - Centre of Excellence in Paediatrics (Rooftop of Children's Hospital)							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L <sub>eq</sub>	L <sub>10</sub>	L <sub>90</sub>	L <sub>eq</sub>	L <sub>eq</sub>
3-Jan-25	14:55	Fine	69.1	70.6	63.8	78.0	69.1 Measured ≤ Baseline
9-Jan-25	13:00	Sunny	69.9	72.5	66.8	78.0	69.9 Measured ≤ Baseline
15-Jan-25	12:00	Fine	67.7	68.9	66.4	78.0	67.7 Measured ≤ Baseline
21-Jan-25	14:48	Sunny	70.7	71.8	69.2	78.0	70.7 Measured ≤ Baseline
27-Jan-25	12:10	Fine	65.6	66.6	64.4	78.0	65.6 Measured ≤ Baseline

Location KER1 - Future Residential Development at Kerry Godown							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L <sub>eq</sub>	L <sub>10</sub>	L <sub>90</sub>	L <sub>eq</sub>	L <sub>eq</sub>
3-Jan-25	10:25	Fine	69.0	72.6	61.2	65.0	67
9-Jan-25	16:00	Sunny	73.1	74.6	71.0	65.0	72
15-Jan-25	13:00	Fine	74.9	78.3	67.0	65.0	74
21-Jan-25	15:33	Sunny	73.1	73.9	65.8	65.0	72
27-Jan-25	14:05	Fine	75.1	79.2	62.7	65.0	75




Location KTD2d - Next to the SOR Office of Trunk Road T2 in Kai Tak Area							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L <sub>eq</sub>	L <sub>10</sub>	L <sub>90</sub>	L <sub>eq</sub>	L <sub>eq</sub>
3-Jan-25	15:40	Fine	68.6	70.4	64.2	64.0	67
9-Jan-25	14:00	Sunny	62.3	65.6	55.9	64.0	62 Measured ≤ Baseline
15-Jan-25	14:00	Fine	67.5	70.9	57.7	64.0	65
21-Jan-25	13:46	Sunny	65.9	70.5	56.3	64.0	61
27-Jan-25	13:00	Fine	72.1	76.3	52.2	64.0	71

## Noise Levels



Title Kai Tak Development – Trunk Road T2 and Infrastructure Works at the Former South Apron  Graphical Presentation of Construction Noise Monitoring Results	Date	Project No.	CINOTECH
	Jan 25	MA20003	
		Appendix H	

## Noise Levels



Title Kai Tak Development – Trunk Road T2 and Infrastructure Works at the Former South Apron  Graphical Presentation of Construction Noise Monitoring Results	Date Jan 25	Project No. MA20003	
		Appendix H	