

Appendix G - Noise Monitoring Results

(0700-1900 hrs on Normal Weekdays)

Location CM1 - Nga Lai House, Yau Lai Estate Phase 1, Yau Tong							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
3 Nov 2025	11:07	Cloudy	65.8	66.0	65.6	65.5	54
13 Nov 2025	10:15	Fine	69.1	71.3	66.2	65.5	67
19 Nov 2025	10:21	Cloudy	72.1	75.3	70.9	65.5	71
25 Nov 2025	11:00	Fine	69.7	74.1	61.6	65.5	68




Location CM2 - Bik Lai House, Yau Lai Estate Phase 1, Yau Tong							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
3 Nov 2025	10:13	Cloudy	67.9	69.1	66.2	63.6	66
13 Nov 2025	9:30	Fine	68.9	72.6	64.2	63.6	67
19 Nov 2025	11:15	Cloudy	69.1	72.3	66.5	63.6	68
25 Nov 2025	13:50	Fine	68.9	70.2	67.3	63.6	67

Location CM3 - Block S, Yau Lai Estate Phase 5, Yau Tong							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
3 Nov 2025	12:01	Cloudy	66.6	68.2	64.5	65.6	60
13 Nov 2025	11:15	Fine	65.7	68.4	62.1	65.6	49
19 Nov 2025	11:59	Cloudy	68.2	71.3	64.3	65.6	65
25 Nov 2025	14:30	Fine	69.9	71.4	65.4	65.6	68

Location CM4 - Tin Hau Temple, Cha Kwo Ling							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
3 Nov 2025	10:19	Cloudy	58.5	61.1	54.6	62.0	59 Measured ≤ Baseline
13 Nov 2025	13:20	Fine	58.7	60.5	54.8	62.0	59 Measured ≤ Baseline
19 Nov 2025	15:44	Drizzle	59.7	62.4	55.5	62.0	60 Measured ≤ Baseline
25 Nov 2025	12:30	Fine	67.1	68.0	64.9	62.0	65



Location CM5 - CCC Kei Faat Primary School, Yau Tong							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
3 Nov 2025	12:57	Cloudy	66.9	69.2	62.9	68.2	67 Measured ≤ Baseline
13 Nov 2025	12:00	Fine	66.5	68.7	62.3	68.2	67 Measured ≤ Baseline
19 Nov 2025	12:31	Cloudy	67.9	70.3	63.3	68.2	68 Measured ≤ Baseline
25 Nov 2025	11:50	Fine	69.8	72.6	65.5	68.2	65

Noise Levels



Title Contract No. ED/2018/04 Trunk Road T2 and Infrastructure Works for Developments at the Former South Apron Graphical Presentation of Construction Noise Monitoring Results	Scale N.T.S Date Nov 25	Project No. MA20003 Appendix G	
--	----------------------------------	---	--

Noise Levels



Notes:

- 1) The major activitie(s) being carried out on site during the reporting period is/are presented in Section 1.11
- 2) The weather conditions during the reporting month are presented in Appendix C.
- 3) Other factors which might affect the monitoring results are presented in Section 3.13.

Title Contract No. ED/2018/04 Trunk Road T2 and Infrastructure Works for Developments at the Former South Apron Graphical Presentation of Construction Noise Monitoring Results	Scale	Project	
	N.T.S	No. MA20003	
	Date	Appendix	
	Nov 25	G	